



ALG ORELAP ID #OR100012  
 361 West 5th Ave  
 Eugene, OR 97401  
 TEL: (541) 485-8404 FAX: (541) 484-5995  
 Website:

# Analytical Report

Date Reported 8/1/2016

**WO#:** 1607B12  
**CLIENT:** Central Linn School District  
**Project:** Central Linn Elementary  
**PWS Number:**  
**Sample Source:**

**Received Date:** 7/22/2016 2:35:00 PM  
**Sampler Name:** Joni Wixom  
**Matrix:** Drinking Water  
**Sample Type:**

Lab ID:	Client Sample ID			Collection Date:				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.156	0.0200	0.0200	*	mg/L	7/30/2016 7:15:00 AM	KG
Lab ID:	Client Sample ID			Collection Date:				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0104	0.0200	0.00200		mg/L	7/28/2016 2:25:00 PM	KG
Lab ID:	Client Sample ID			Collection Date:				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/28/2016 2:25:00 PM	KG
Lab ID:	Client Sample ID			Collection Date:				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0159	0.0200	0.00200		mg/L	7/28/2016 2:25:00 PM	KG
Lab ID:	Client Sample ID			Collection Date:				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/28/2016 2:25:00 PM	KG
Lab ID:	Client Sample ID			Collection Date:				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00663	0.0200	0.00200		mg/L	7/28/2016 2:25:00 PM	KG
Lab ID:	Client Sample ID			Collection Date:				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00457	0.0200	0.00200		mg/L	7/28/2016 2:25:00 PM	KG
Lab ID:	Client Sample ID			Collection Date:				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0106	0.0200	0.00200		mg/L	7/28/2016 2:25:00 PM	KG

- Qualifiers:**
- \* Value exceeds Maximum Contaminant Level (MCL)
  - C Value is below Minimum Compound Limit.
  - H Holding times for preparation or analysis exceeded
  - MCL Maximum Contaminant Level
  - ND Not Detected at the Reporting Limit
  - A Accredited by ORELAP
  - E Value above quantitation range
  - LOD Limit of Detection
  - NAR See note in Case Narrative
  - PL Permit Limit



ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

# Analytical Report

Date Reported **8/1/2016**

**WO#:** 1607B12  
**CLIENT:** Central Linn School District  
**Project:** Central Linn Elementary  
**PWS Number:**  
**Sample Source:**

**Received Date:** 7/22/2016 2:35:00 PM  
**Sampler Name:** Joni Wixom  
**Matrix:** Drinking Water  
**Sample Type:**

Lab ID:	Client Sample ID	Location	Collection Date:					
1607B12-009	Kitchen		7/19/2016 7:34:00 AM					
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00508	0.0200	0.00200		mg/L	7/28/2016 2:25:00 PM	KG

- Qualifiers:**
- \* Value exceeds Maximum Contaminant Level (MCL)
  - C Value is below Minimum Compound Limit.
  - H Holding times for preparation or analysis exceeded
  - MCL Maximum Contaminant Level
  - ND Not Detected at the Reporting Limit
  - A Accredited by ORELAP
  - E Value above quantitation range
  - LOD Limit of Detection
  - NAR See note in Case Narrative
  - PL Permit Limit



Ensuring quality  
just best results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

# Analytical Report

Date Reported **8/1/2016**

**WO#:** 1607B11  
**CLIENT:** Central Linn School District  
**Project:** Central Linn Junior High/High School  
**PWS Number:**  
**Sample Source:**

**Received Date:** 7/22/2016 2:35:00 PM  
**Sampler Name:** Joni Wixom  
**Matrix:** Drinking Water  
**Sample Type:**

Lab ID:	Client Sample ID	Boiler Room	Collection Date:					
1607B11-001	Boiler Room		7/19/2016 7:54:00 AM					
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00891	0.0200	0.00200		mg/L	7/30/2016 7:15:00 AM	KG
Lab ID:	Client Sample ID	MS Water Fountain	Collection Date:					
1607B11-002	MS Water Fountain		7/19/2016 7:57:00 AM					
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/28/2016 2:25:00 PM	KG
Lab ID:	Client Sample ID	Main RS Rms	Collection Date:					
1607B11-003	Main RS Rms		7/19/2016 8:03:00 AM					
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/28/2016 2:25:00 PM	KG
Lab ID:	Client Sample ID	Lobby Fountain	Collection Date:					
1607B11-004	Lobby Fountain		7/19/2016 8:06:00 AM					
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/28/2016 2:25:00 PM	KG
Lab ID:	Client Sample ID	Kitchen	Collection Date:					
1607B11-005	Kitchen		7/19/2016 8:10:00 AM					
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00886	0.0200	0.00200		mg/L	7/28/2016 2:25:00 PM	KG
Lab ID:	Client Sample ID	Rm 105	Collection Date:					
1607B11-006	Rm 105		7/19/2016 8:17:00 AM					
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0134	0.0200	0.00200		mg/L	7/30/2016 7:15:00 AM	KG

**Qualifiers:**

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit