



ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported 8/1/2016

WO#: 1607B12
CLIENT: Central Linn School District
Project: Central Linn Elementary
PWS Number:
Sample Source:

Received Date: 7/22/2016 2:35:00 PM
Sampler Name: Joni Wixom
Matrix: Drinking Water
Sample Type:

Lab ID: 1607B12-001 **Client Sample ID:** Boiler Room **Collection Date:** 7/19/2016 7:06:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.156	0.0200	0.0200	*	mg/L	7/30/2016 7:15:00 AM	KG

Lab ID: 1607B12-002 **Client Sample ID:** South Hall Fountain **Collection Date:** 7/19/2016 7:13:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0104	0.0200	0.00200		mg/L	7/28/2016 2:25:00 PM	KG

Lab ID: 1607B12-003 **Client Sample ID:** Center Hall Fountain **Collection Date:** 7/19/2016 7:16:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/28/2016 2:25:00 PM	KG

Lab ID: 1607B12-004 **Client Sample ID:** Rm 3 **Collection Date:** 7/19/2016 7:20:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0159	0.0200	0.00200		mg/L	7/28/2016 2:25:00 PM	KG

Lab ID: 1607B12-005 **Client Sample ID:** Middle Hall Fountain **Collection Date:** 7/19/2016 7:22:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/28/2016 2:25:00 PM	KG

Lab ID: 1607B12-006 **Client Sample ID:** Staff Rm **Collection Date:** 7/19/2016 7:26:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00663	0.0200	0.00200		mg/L	7/28/2016 2:25:00 PM	KG

Lab ID: 1607B12-007 **Client Sample ID:** Lobby Bathrooms **Collection Date:** 7/19/2016 7:29:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00457	0.0200	0.00200		mg/L	7/28/2016 2:25:00 PM	KG

Lab ID: 1607B12-008 **Client Sample ID:** Lobby Fountain **Collection Date:** 7/19/2016 7:31:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0106	0.0200	0.00200		mg/L	7/28/2016 2:25:00 PM	KG

Qualifiers:

- * Value exceeds Maximum Contaminant Level (MCL)
- C Value is below Minimum Compound Limit.
- H Holding times for preparation or analysis exceeded
- MCL Maximum Contaminant Level
- ND Not Detected at the Reporting Limit

- A Accredited by ORELAP
- E Value above quantitation range
- LOD Limit of Detection
- NAR See note in Case Narrative
- PL Permit Limit



ANALYTICAL LABORATORY GROUP

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported **8/1/2016**

WO#: 1607B12
CLIENT: Central Linn School District
Project: Central Linn Elementary
PWS Number:
Sample Source:

Received Date: 7/22/2016 2:35:00 PM
Sampler Name: Joni Wixom
Matrix: Drinking Water
Sample Type:

Lab ID: 1607B12-009 **Client Sample ID:** Kitchen **Collection Date:** 7/19/2016 7:34:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00508	0.0200	0.00200		mg/L	7/28/2016 2:25:00 PM	KG

- Qualifiers:**
- * Value exceeds Maximum Contaminant Level (MCL)
 - C Value is below Minimum Compound Limit.
 - H Holding times for preparation or analysis exceeded
 - MCL Maximum Contaminant Level
 - ND Not Detected at the Reporting Limit
 - A Accredited by ORELAP
 - E Value above quantitation range
 - LOD Limit of Detection
 - NAR See note in Case Narrative
 - PL Permit Limit



Drinking Water
just best reports

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported 8/1/2016

WO#: 1607B11
CLIENT: Central Linn School District
Project: Central Linn Junior High/High School
PWS Number:
Sample Source:

Received Date: 7/22/2016 2:35:00 PM
Sampler Name: Joni Wixom
Matrix: Drinking Water
Sample Type:

Lab ID: 1607B11-001 **Client Sample ID:** Boiler Room **Collection Date:** 7/19/2016 7:54:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00891	0.0200	0.00200		mg/L	7/30/2016 7:15:00 AM	KG

Lab ID: 1607B11-002 **Client Sample ID:** MS Water Fountain **Collection Date:** 7/19/2016 7:57:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/28/2016 2:25:00 PM	KG

Lab ID: 1607B11-003 **Client Sample ID:** Main RS Rms **Collection Date:** 7/19/2016 8:03:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/28/2016 2:25:00 PM	KG

Lab ID: 1607B11-004 **Client Sample ID:** Lobby Fountain **Collection Date:** 7/19/2016 8:06:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/28/2016 2:25:00 PM	KG

Lab ID: 1607B11-005 **Client Sample ID:** Kitchen **Collection Date:** 7/19/2016 8:10:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00886	0.0200	0.00200		mg/L	7/28/2016 2:25:00 PM	KG

Lab ID: 1607B11-006 **Client Sample ID:** Rm 105 **Collection Date:** 7/19/2016 8:17:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0134	0.0200	0.00200		mg/L	7/30/2016 7:15:00 AM	KG

Qualifiers:

- * Value exceeds Maximum Contaminant Level (MCL)
- C Value is below Minimum Compound Limit.
- H Holding times for preparation or analysis exceeded
- MCL Maximum Contaminant Level
- ND Not Detected at the Reporting Limit
- A Accredited by ORELAP
- E Value above quantitation range
- LOD Limit of Detection
- NAR See note in Case Narrative
- PL Permit Limit

Original